

ment

ng, Rajmahal Road,
Ph. (O) 0265 2432050



Vadodara Mahanagar Seva Sadan

Dy. Health Officer (North)

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

DATE :- 13/05/2026

It is certified that an inspection team headed by Dr. Chetna Patel – Deputy Health Officer (NZ) from Vadodara Municipal Corporation (Health Department) inspected the **Shannen International School**, Canal Rd, opp. Pancham Party Plot, New Sama, Vadodara, Gujarat 390024 on **13-05-2026** and found that **Shannen International School** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T Govt.

The above is valid for a period of one year



Signature with seal.....
Deputy Health Officer (North Zone)
Vadodara Municipal Corporation
Name:- Dr. Chetna Patel
Designation :- Deputy Health Officer (NZ)
Name and Address of the
Office / Department :- Ward No 2 Office Near
Ayyappa Ground, Sama



PUBLIC HEALTH LABORATORY

VADODARA MUNICIPAL CORPORATION

(NABL Accredited Testing Laboratory as per ISO/IEC 17025 : 2017)



Name and address of Customer (#):
SHANNEN INTERNATIONAL SCHOOL
NEAR PODAR SCHOOL, SAMA, VADODARA.

Test Report No : PHL/PW/0534/2026
Test Report Issue Date : 10-04-2026
Sample Code No. : PW/0517/2026
Sample Received Date : 04-04-2026
ULR Number : TC955926000001218F

Test Report

- (i) Kind of Sample (#) : Drinking Water (R.O.)
(ii) Sample Description : 1 litre water sample received in plastic bottle.
(iii) Sample Condition : Received in good condition.
(iv) Physical Appearance : A clear colourless liquid.
(v) Date of Performance : 04-04-2026 to 10-04-2026.
(vi) Location of Performance : Water Testing Lab.
(vii) Discipline : Chemical.
(viii) Group : Water.

Sr. No.	Quality Characteristic	Name of Method of Test Used	Result	IS 10500:2012 (2 nd Revision)	
				Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
				Max.	Max.
1	Colour, Hazen unit	APHA (24 th Ed.2022), Method: 2120 B	2	5	15
2	Odour	IS 3025 (Part-5) : 2018	Agreeable	Agreeable	Agreeable
3	Turbidity, NTU	APHA (24 th Ed.2022), Method: 2130 B	0.18	1	5
4	pH at 25°C	APHA (24 th Ed.2022), Method: 4500 H ⁺ B	7.89	6.5 to 8.5	No relaxation
5	Conductivity at 25°C, $\mu\text{S}/\text{cm}$	APHA (24 th Ed.2022), Method: 2510 B	959.00	-	-
6	Total Dissolved Solids, mg/L	APHA (24 th Ed.2022), Method: 2540 C	600.00	500	2000
7	Total Hardness (as CaCO_3), mg/L	APHA (24 th Ed.2022), Method: 2340 C	160.00	200	600
8	Calcium (as Ca^{+2}), mg/L	APHA (24 th Ed.2022), Method: 3500 Ca^{+2} B	35.27	75	200
9	Magnesium (as Mg^{+2}), mg/L	APHA (24 th Ed.2022), Method: 3500 Mg^{+2} B	17.45	30	100
10	Chloride (as Cl^-), mg/L	APHA (24 th Ed.2022), Method: 4500 Cl^- B	88.00	250	1000
11	Sulphate (as SO_4^{-2}), mg/L	APHA (24 th Ed.2022), Method: 4500 SO_4^{-2} E	65.33	200	400
12	Nitrate (as NO_3^-), mg/L	APHA (24 th Ed.2022), Method: 4500 NO_3^- B	43.23	45	No relaxation
13	Fluoride (as F^-), mg/L	APHA (24 th Ed.2022), Method: 4500 F^- C	0.59	1	1.5
14	Total Alkalinity (as CaCO_3), mg/L	APHA (24 th Ed.2022), Method: 2320 B	244.00	200	600

Note : Above tests are accredited by NABL

Opinion: In respect of test performed as above, the sample Complies with standard requirement of IS 10500 : 2012 (2nd revision) for drinking water.



(M. L. Patel)
Food Analyst
Public Health Laboratory
Vadodara Municipal Corporation

Note:

1. This Report is refers only to particular sample submitted for testing.
2. This Report is not to be used for the purpose of Advertisement or Legal action.
3. Information marked with “#” is provided by the customer.

****End of Test Report****



PUBLIC HEALTH LABORATORY

VADODARA MUNICIPAL CORPORATION

Name and address of Customer (#):
SHANNEN INTERNATIONAL SCHOOL
NEAR PODAR SCHOOL, SAMA, VADODARA.

Test Report No : PHL/PW/0534/2026
Test Report Issue Date : 10-04-2026
Sample Code No. : PW/0517/2026
Sample Received Date : 04-04-2026

Test Report

- (i) Kind of Sample (#) : Drinking Water (R.O.)
(ii) Sample Description : 1 litre water sample received in plastic bottle.
(iii) Sample Condition : Received in good condition.
(iv) Physical Appearance : A clear colourless liquid.
(v) Date of Performance : 04-04-2026 to 10-04-2026.
(vi) Location of Performance : Water Testing Lab.
(vii) Discipline : Chemical and Biological.
(viii) Group : Water.

Sr. No.	Quality Characteristic	Name of Method of Test Used	Result	IS 10500:2012 (2nd Revision)	
				Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
				Max.	Max.
1	Residual Free Chlorine, mg/L	FSSAI Manual Method For Analysis of Foods (Water), 2016	Nil	0.2*	1.0
2	E. Coli	FSSAI Manual Method For Analysis of Foods (Water), 2016	Absent	shall not be detectable in any 100 ml sample	No relaxation

Note : Above tests are not accredited by NABL.

Opinion: In respect of test performed as above, the sample Complies with standard requirement of IS 10500 : 2012 (2nd revision) for drinking water.



(M. L. Patel)
Food Analyst
Public Health Laboratory
Vadodara Municipal Corporation

Note:

1. This Report is refers only to particular sample submitted for testing.
2. This Report is not to be used for the purpose of Advertisement or Legal action.
- 3*. To be applicable only when water is chlorinated.
- 4*. When protection against viral infection is required, it should be minimum 0.5 mg/L.
5. Information marked with “#” is provided by the customer.

****End of Test Report****